

DATE	REVISION
A 1.10.09	MOVEABLE WALL ADDED TO P102. P102/102a RENUMBERED TO SUIT.
B 30.7.10	P116-118 COMBINED TO FORM TWO OFFICES
C 1.2.11	GENERAL UPDATE FOLLOWING FSO SURVEY
D 27.6.11	UPDATE FOLLOWING SURVEY WORK FOR P103 WORKS
E 19.8.11	P103 CONVERTED TO BOOTHS, WAITING AREA & STORE.
F 11.1.12	P106 UPDATED TO "PSYCHOLOGY PC LAB"
G 23.7.12	UPDATE FOLLOWING WORKS TO FORM ROOMS P126, P126a & P127
H 31.10.13	PC BOOTH FACILITY IN P103 AREA EXTENDED.
	STAIR 4 AREA ADJACENT STEVENSON LT UPDATED.
J 27.11.14	UPDATE FOLLOWING LIFT INSTALLATION TO STEVENSON LT.
K 24.6.15	UPDATE FOLLOWING FSO'S SURVEY
L 18.4.16	PLAN CORRECTED TO SHOW REFUGE P154, FORMED AS PART OF PLATFORM LIFT INSTALL. FOR STEVENSON LT.
M 29.9.16	P153 DOOR, LAYOUT & CAPACITY UPDATED. EXTINGUISHER POSITIONS & TYPES UPDATED.
N 25.8.17	P101 CAPACITY UPDATED & DOOR INFILLED
P 11.6.18	P111 CHANGED TO "BOOTH"
Q 9.1.19	P111 CHANGED TO "HOTDESK"
R 4.4.19	UPDATE FOLLOWING SURVEY & WORKS TO CAVITY BARRIERS
S 18.4.19	UPDATE FOLLOWING WORKS TO FORM P103g & P103r.



- Key to Fire Symbols (existing)
- Existing fire resisting construction 30 min.
 - Existing Evac chair
 - Existing wheelchair refuge zone
 - Existing wet chemical fire extinguisher
 - Existing fire blanket
 - Existing 6 litre P50 foam fire extinguisher
 - Existing call point – manual
 - Existing exit sign – internally illuminated
 - Existing emergency lighting luminaire
 - Existing audible warning device – bell
 - Existing visual warning device
 - Existing smoke detector
 - Existing combined smoke detector & sounder
 - Existing heat detector
 - Existing heat detectors
 - Existing pushbar door ironmongery
 - Existing fire exit sign
 - Existing fire action sign – general
 - Denotes directional arrow on existing fire exit sign
 - Existing emergency door release call point – manual
 - Existing dry riser outlet

FR /cavity barrier lines are based on a survey & remedial works carried out by Oak Leaf & Nene Valley Fire. Some doors may have "Fire Door" signage attached but be within a wall that is not shown as FR on this plan. This is because some walls have been assessed as non-FR compliant during the survey & remedial works. Therefore, these doors & walls should be regarded as non-FR.

THIS FIRE SAFETY PLAN IS GENERALLY BASED ON INFORMATION PROVIDED BY BU'S FIRE SAFETY OFFICER. IT IS THE RESPONSIBILITY OF ALL USERS OF THIS PLAN TO CHECK THE INFORMATION PROVIDED TO CONFIRM THE EXACT POSITIONS OF THE FIRE SAFETY EQUIPMENT, CAVITY BARRIERS ETC.

FIRST FLOOR
FIRE PLAN

POOLE HOUSE:
MAIN BLOCK

PH/M/FP/2S

SCALE 1:250 at A3
NOVEMBER 2008

